




- ### GENERAL NOTES
1. ALL DIMENSIONS ARE GIVEN IN MILLIMETERS UNLESS OTHERWISE INDICATED.
 2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE SCOPE OF WORKS. ANY DISCREPANCIES ARE TO BE BROUGHT TO THE ATTENTION OF KELLIHERS FOR CLARIFICATION PRIOR TO ANY WORK COMMENCING.
 3. CONTRACTOR TO FIELD VERIFY ALL DIMENSIONS. DISCREPANCIES ARE TO BE NOTIFIED TO THE CONTRACTOR AND DESIGN FOR RESOLUTION.
 4. ALL WORKS TO COMPLY WITH PREVIOUSLY AGREED AND ISSUED SPECIFICATIONS

- ### LEGEND
- Site center
Results - Horizontal Illuminance (lux)
Eav= 7.85
Emin= 1.67
Emax= 16.00
Emin/Emax= 0.10
Emin/Eav= 0.21
Emax/Eav= 2.04
- Site east
Results - Horizontal Illuminance (lux)
Eav= 8.22
Emin= 1.89
Emax= 17.22
Emin/Emax= 0.11
Emin/Eav= 0.23
Emax/Eav= 2.09
- Luminaire Data
Luminaire A LumiStreet gen2 Eco Lamp
LED40 L95@100kh /730 T25 MF 0.80
Luminaire B LumiStreet gen2 Eco Lamp
LED27 L96@100kh /730 T25 MF 0.80
- Key
● Luminaire A Column
● Luminaire B Column
○ Beam Aiming Target
□ Photometric Centre
- All Dimensions in metres



△ LAYOUT REVISED - REISSUED FOR APPROVAL	DMD	PS	PS	11JUN25
△ ISSUED FOR COUNCIL APPROVAL	DMD	PS	PS	15MAY25
REV. NO. REVISION DESCRIPTION	DATE	BY	CHECKED	APPROVED
THIS DRAWING CONTAINS INFORMATION WHICH IS THE PROPERTY OF KELLIHERS LTD. THIS DRAWING IS PROVIDED IN CONFIDENCE AND ITS CONTENTS MAY NOT BE DISCLOSED WITHOUT THE PRIOR WRITTEN CONSENT OF KELLIHERS LIMITED.				
PROJECT: MAGLIN LANDS KELLIHERS ELECTRICAL LTD., M50 BUSINESS PARK, BALLINMOUNT, DUBLIN 12.				
APPROVALS				
DESIGNED	DMD	15MAY25		
REVIEWED	DMD	15MAY25		
APPROVED	PS	15MAY25		
DATE	DMD	15MAY25		
ENGINEER	PS	15MAY25		
APPROVED	PS	15MAY25		
EST. CODE	PHILLIPS			
PROJECT NO. KE/MLB/01 TO FIT		DRAWING NO. KE/MLB/01 1/500@BAO	SHEET 1 OF 3	

N22